

## Sampling Results Regarding the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station

Unit: Bq/L

	Seawater of the south water outlet <sup>Note 1</sup> (near the exit of the side ditch) (T-2)	Confluence of drainage channel B and C <sup>Note 2</sup> (C-1)
Date of Sampling	Aug 23, 2013	Aug 23, 2013
Time of sampling	12:25 PM	1:00 PM
Cs-134(Approx. 2 years)	1.2	ND(18)
Cs-137(Approx.30 years)	2.5	ND(26)
All β	ND(20)	150

Note 1: Approx. 330m south from Unit 1-4 water outlet (T-2)

Note 2: Same sampling point as side ditch in front of the core warehouse sampled on August 19 (announced on August 20) and August 20 (announced on August 21)

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.