

Sampling Results Regarding the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station

Unit: Bq/L

| | Seawater of the south water outlet ^{Note 1} (near the exit of the side ditch) (T-2) | Confluence of drainage channel B and C ^{Note 2} (C-1) |
|-------------------------|---|---|
| Date of Sampling | Aug 25, 2013 | Aug 25, 2013 |
| Time of sampling | 11:05 AM | 11:20 AM |
| Cs-134(Approx. 2 years) | ND(1.2) | ND(19) |
| Cs-137(Approx.30 years) | ND(1.5) | ND(27) |
| All β | ND(18) | 150 |

Note 1: Approx. 330m south from Unit 1-4 water outlet (T-2)

Note 2: Same sampling point as side ditch in front of the core warehouse sampled on August 19 (announced on August 20) and August 20 (announced on August 21)

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.