## Sampling Results Regarding the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station

Unit: Bq/L

	Seawater of the south water outlet Note (near the exit of the side ditch) (T-2)	Confluence of drainage channel B and C <sup>Note 2</sup> (C-1)
Date of Sampling	Aug 26, 2013	Aug 26, 2013
Time of sampling	9:38 AM	9:55 AM
Cs-134(Approx. 2 years)	ND(1.4)	ND(19)
Cs-137(Approx.30 years)	ND(1.3)	ND(27)
ΑΙΙ β	ND(19)	86

Note 1: Approx. 330m south from Unit 1-4 water outlet (T-2)

Note 2: Same sampling point as side ditch in front of the core warehouse sampled on August 19 (announced on August 20) and August 20 (announced on August 21)

<sup>\* &</sup>quot;ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.