

Sampling Results Regarding the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station

Unit: Bq/L

	Seawater of the south water outlet ^{Note 1} (near the exit of the drainage channel) (T-2)	Near Fureai intersection at drainage channel B ^{Note 2} (B-0-1)	Near maingate at drainage channel C ^{Note 2} (C-0)	Confluence of drainage channel B and C ^{Note 3} (C-1)	Drainage channel C OP.30 exit (C-2)
Date of Sampling	Aug 30, 2013	Aug 30, 2013	Aug 30, 2013	Aug 30, 2013	Aug 30, 2013
Time of sampling	10:05 AM	2:30 PM	2:10 PM	11:00 AM	1:55 PM
Cs-134(Approx. 2 years)	ND(1.2)	ND(21)	ND(19)	ND(18)	ND(19)
Cs-137(Approx.30 years)	ND(1.3)	31	ND(26)	ND(25)	ND(26)
All β	ND(18)	71	ND(15)	240	290

Note 1: Approx. 330m south from Unit 1-4 water outlet (T-2)

Note 2: Water inflow location of drainage channel to the tank area

Note 3: Same sampling point as side ditch in front of the core warehouse sampled on August 19 (announced on August 20) and August 20 (announced on August 21)

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.