

Sampling Results Regarding the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (South Water Outlet, Drainage Channel)

Unit: Bq/L

| | Seawater of the south water outlet ^{Note 1} (near the exit of the drainage channel) (T-2) | Confluence of drainage channel B and C ^{Note 2} (C-1) | Sampling points of the inside of drainage channel B | | | Near Fureai intersection at drainage channel B ^{Note 3} (B-0-1) | Near maingate at drainage channel C ^{Note 3} (C-0) | Drainage channel C OP.30 exit (C-2) |
|-------------------------|--|--|---|-------------------------|--|--|---|-------------------------------------|
| | | | Location where high radiation was detected on August 21 (B-1) | Downstream of B-1 (B-2) | In front of the confluence of drainage channel C (B-3) | | | |
| Date of Sampling | Sep 7, 2013 | Sep 7, 2013 | Sep 7, 2013 | Sep 7, 2013 | Sep 7, 2013 | Sep 7, 2013 | Sep 7, 2013 | Sep 7, 2013 |
| Time of sampling | 4:00 PM | * | * | * | * | 11:24 AM | 11:33 AM | 4:15 PM |
| Cs-134(Approx. 2 years) | ND(1.9) | * | * | * | * | ND(19) | ND(19) | ND(19) |
| Cs-137(Approx.30 years) | 1.9 | * | * | * | * | ND(26) | ND(26) | ND(26) |
| All β | ND(18) | * | * | * | * | 100 | ND(13) | 20 |

Note 1: Approx. 330m south from Unit 1-4 water outlet (T-2)

Note 2: Same sampling point as side ditch in front of the core warehouse sampled on August 19 (announced on August 20) and August 20 (announced on August 21)

Note 3: Water inflow location of drainage channel to the tank area

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* No sampling due to the cleaning at the drainage channel B.

