


Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area) (1/2)

Unit: Bq/L

	Groundwater around H4 area				
	E-1	E-2	E-3	E-4	E-5
Date of Sampling	/	Sep 7, 2013	/	/	/
Time of sampling	/	11:40 AM	/	/	/
All β	/	35	/	/	/
H-3 (Approx. 12 years)	/	300	/	/	/

* Data announced this time is provided in a thick-frame. The other data was announced on September 8.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.



Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area) (2/2)

Unit: Bq/L

		Groundwater around H4 area				
		E-1	E-2	E-3	E-4	E-5
Date of Sampling		Sep 8, 2013	Sep 8, 2013			
Time of sampling		9:20 AM	9:50 AM			
Cs-134 (Approx. 2 years)		2.5	0.64			
Cs-137 (Approx.30 years)		5.1	0.74			
The other Y						
All β		3200	67			
H-3 (Approx. 12 years)		Under analysis	Under analysis			

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

