


## Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area) (1/2)

Unit: Bq/L

	Groundwater around H4 area				
	E-1	E-2	E-3	E-4	E-5
Date of Sampling	Sep 14, 2013	Sep 14, 2013	/	/	/
Time of sampling	10:20 AM	10:10 AM	/	/	/
All $\beta$	1,100	21	/	/	/
H-3 (Approx. 12 years)	170,000	360	/	/	/

\* Data announced this time is provided in a thick-frame. The other data was announced on September 15.

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.



## Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area) (2/2)

Unit: Bq/L

	Groundwater around H4 area				
	E-1	E-2	E-3	E-4	E-5
Date of Sampling	Sep 15, 2013	Sep 15, 2013	/	9月15日	/
Time of sampling	11:30 AM	11:40 AM	/	11:58	/
All $\beta$	1,100	35	/	1,300	/
H-3 (Approx. 12 years)	Under analysis	Under analysis	/	Under analysis	/

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

