


## Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area) (1/2)

Unit: Bq/L

	Groundwater around H4 area				
	E-1	E-2	E-3	E-4	E-5
Date of Sampling	Sep 16, 2013	Sep 16, 2013		Sep 16, 2013	
Time of sampling	9:05 AM	9:10 AM		9:15 AM	
All $\beta$	560	31		18	
H-3 (Approx. 12 years)	95,000	430		410	



## Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area) (2/2)

Unit: Bq/L

	Groundwater around H4 area				
	E-1	E-2	E-3	E-4	E-5
Date of Sampling	Sep 17, 2013	Sep 17, 2013	/	Sep 17, 2013	/
Time of sampling	9:25 AM	9:30 AM	/	9:20 AM	/
All $\beta$	360	33	/	53	/
H-3 (Approx. 12 years)	Under analysis	Under analysis	/	Under analysis	/

