

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Pump Well)

Unit: Bq/L

	Pump wells of the groundwater bypass							
	No.5	No.6	No.7	No.8	No.9	No.10	No.11	No.12
Date of Sampling	Sep 17, 2013	Sep 17, 2013	Sep 17, 2013	Sep 17, 2013	Sep 17, 2013	Sep 17, 2013	Sep 17, 2013	Sep 17, 2013
Time of sampling	9:00 AM	9:05 AM	9:10 AM	9:12 AM	9:15 AM	9:18 AM	9:25 AM	9:30 AM
All β	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)
Tritium	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.