

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

Unit: Bq/L

	Groundwater around H4 area					
	E-1	E-2	E-3	E-4	E-5	E-6
Date of Sampling	Sep 20, 2013	Sep 20, 2013	Sep 20, 2013	Sep 20, 2013	/	Sep 20, 2013
Time of sampling	9:25 AM	9:30 AM	9:40 AM	9:35 AM		2:00 PM
All β	370	42	510	51		46
H-3 (Approx. 12 years)	110,000	410	ND(120)	200		310

* Data announced this time is provided in a thick-frame. The other data was announced on September 20.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

