

## Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

Unit: Bq/L

	Groundwater around H4 area					
	E-1	E-2	E-3	E-4	E-5	E-6
Date of Sampling	Sep 24, 2013	Sep 24, 2013	Sep 24, 2013	Sep 24, 2013	Sep 24, 2013	/
Time of sampling	9:50 AM	9:55 AM	10:20 AM	10:15 AM	10:10 AM	
All $\beta$	260	35	360	ND(17)	100	
H-3 (Approx. 12 years)	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

