

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

Unit: Bq/L

	Groundwater around H4 area					
	E-1	E-2	E-3	E-4	E-5	E-6
Date of Sampling	Sep 28, 2013	Sep 28, 2013	Sep 28, 2013	Sep 28, 2013	Sep 28, 2013	
Time of sampling	8:00 AM	8:08 AM	8:31 AM	8:22 AM	8:15 AM	
All β	170	110	200	26	46	
H-3 (Approx. 12 years)	140,000	470	150	210	1000	

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

