Sampling Results Regarding the Water Leak at the Tanks in the H4 area and the B area in Fukushima Daiichi Nuclear Power Station (South Water Outlet, Drainage Channel)

Unit: Bq/L

	Seawater of the south water outlet Note 1 (near the drainage channel exit) *1 (T-2)	Junction of the drainage channels B and C Note 2 (C-1)	Side ditch next to the tank (X-2)	Side ditch next to the tank (point immediately short of the junction with the drainage channel C) (X-1)	drainage channel C and the side ditch	Sampling points of the inside of drainage channel B					
						high dose equivalent		Point immediately short of the junction with the drainage channel C (B-3)	Point near Fureai Intersection in the drainage channel B Note 3 (B-0-1)	Point near the main gate in the drainage channel C Note 3 (C-0)	Drainage channel C
Date of Sampling	Oct 21, 2013	Oct 21, 2013	Oct 21, 2013	Oct 21, 2013	Oct 21, 2013	Oct 21, 2013	Oct 21, 2013	Oct 21, 2013	Oct 21, 2013	Oct 21, 2013	Oct 21, 2013
Time of sampling	10:30 AM	11:30 AM	12:05 PM	12:00 PM	11:55 AM	11:45 AM	11:40 AM	11:35 AM	11:10 AM	11:20 AM	10:40 AM
Cs-134(Approx. 2 years)	ND(1.3)	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	ND(20)
Cs-137(Approx.30 years)	ND(1.4)	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	ND(26)
ΑΙΙ β	ND(18)	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	1,300

Note 1: Approx. 330m south from Unit 1-4 water outlet (T-2)

Note 2: Same sampling point as side ditch in front of the core warehouse sampled on August 19 (announced on August 20) and August 20 (announced on August 21)

Note 3: Water inflow location of drainage channel to the tank area

^{* &}quot;ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

