Nuclides Analysis Result of the Sub-drain Water in the Surroundings of the Central Radioactive Waste Treatment Facility

I-131(Bq/cm³)

Sampling	After tra	After transfer																	
Location	Mar 17		Mar 19	Mar 20	Mar 21	Mar 22	Mar 23	Mar 24	Mar 25	Mar 26	Mar 27	Mar 28	Mar 29	Mar 30	Mar 31	Apr 1			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
[ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			

Cs-134(Bq/cm³)

Sampling																			
Location	Mar 17	Mar 18	Mar 19	Mar 20	Mar 21	Mar 22	Mar 23	Mar 24	Mar 25	Mar 26	Mar 27	Mar 28	Mar 29	Mar 30	Mar 31	Apr 1			
	ND	ND																	
	ND	ND																	
	ND	ND																	
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	ND	ND																	
	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND			
	0.1	0.16	0.052	0.098	0.048	0.042	0.11	0.098	0.06	0.047	0.05	0.11	0.045	0.095	0.11	0.11			
	ND	ND																	
	ND	ND																	

Cs-137(Bq/cm³)

Sampling																			
Location	Mar 17	Mar 18	Mar 19	Mar 20	Mar 21	Mar 22	Mar 23	Mar 24	Mar 25	Mar 26	Mar 27	Mar 28	Mar 29	Mar 30	Mar 31	Apr 1			
	ND	ND																	
	ND	ND																	
	ND	ND																	
	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
	ND	ND																	
	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND			
	0.18	0.32	0.11	0.18	0.081	0.07	0.19	0.2	0.13	0.092	0.091	0.2	0.077	0.2	0.22	0.2			
	ND	ND																	
	ND	ND																	

- * Hyphen "-" indicates that neither sampling nor measurement was implemented.
- * was selected as a sampling location in the upstream of groundwater (sampling done once a week starting from April 29, 2011) since it became unable to do sampling at
- * Sampling at (located in the downstream of the groundwater) has been done since May 26, 2011.
- * Samping at since May 30, 2011
- * Sampling at has been done since August 2, 2011
- * "ND" indicates that the measurement result is below the detection limit.

I-131: Approx. 0.01Bq/cm³, Cs-134: Approx.0.02Bq/cm³, Cs-137: Approx.0.02Bq/cm³ (April 1, 2013)

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

<Place of Sampling>

Southeast of Unit 4 Turbine Building

Northeast of the Process Main Building

Southeast of the Process Main Building

Southwest of the Process Main Building

South Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building

Southwest Part of the On-site Bunker Building

West Side of the Incineration Workshop Building

North Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building Southeast Part of the On-site Bunker Building