Nuclides Analysis Result of the Sub-drain Water in the Surroundings of the Central Radioactive Waste Treatment Facility

I-131(Bq/cm3)

I-131(Bo	/cm³)																				
Sampling	After tra	fter transfer																			
Location	Mar 31	Apr 1	Apr 2	Apr 3	Apr 4	Apr 5	Apr 6	Apr 7	Apr 8	Apr 9	Apr 10	Apr 11	Apr 12	Apr 13	Apr 14	Apr 15	Apr 16	Apr 17			
1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
4	-	-	-	_	-	-	-	-	-	-	-	-	_	_	_	_	_	-			
5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
6	-	ND	-	_	-	-	-	-	ND	-	-	-			-	ND	_	-			
7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		ļ	
8	ND	ND	ND	ND	ND	ND	ł	ND	ND	ND	.		ND	ND	ND	ND				ļ	
9	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
Cs-134(l	Bq/cm ³)																				
Sampling																					
Location	Mar 31	Apr 1	Apr 2	Apr 3	Apr 4	Apr 5	Apr 6	Apr 7	Apr 8	Apr 9	Apr 10	Apr 11	Apr 12	Apr 13	Apr 14	Apr 15	Apr 16	Apr 17			
1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
4	-	-	-	_	-	-	-	-	-	-	-	-			-	-	_	-			
5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		ļ	
6	-	ND	-	_	-	-	-	-	ND	-	-	-			-	ND	_	-		ļ	
7	0.11	0.11	0.1	0.052	0.096	0.075	0.099	0.059	0.12	0.081	0.079	0.061	0.086	0.098	0.08	0.049		0.074		ļ	
8	ND	ND	ND	ND	0.019	ND	••••••••••••••••••	0.032	0.031	0.018		••••••	ND	ND	ND	ND		ND		ļ	
9	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
Cs-137(l	Bq/cm ³)																				
Sampling																					
Location	Mar 31	Apr 1	Apr 2	Apr 3	Apr 4	Apr 5	Apr 6	Apr 7	Apr 8	Apr 9	Apr 10	Apr 11	Apr 12	Apr 13	Apr 14	Apr 15	Apr 16	Apr 17			
1	ND	ND	ND	ND	ND	ND	ND	0.03	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
4	-	-	-	_	-	-	-	-	-	-	-	-	_	_			_	-			
5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
6	-	ND	-	_	-	-	-	-	ND	-	-	-	_	_	-	ND	_	-			
Ø	0.22	0.2	0.2	0.089	0.2	0.16	0.21	0.15	0.28	0.16	0.17	0.13	0.17	0.19	0.15	0.075	0.12	0.12]]	

* Hyphen "-" indicates that neither sampling nor measurement was implemented.

* 6 was selected as a sampling location in the upstream of groundwater (sampling done once a week starting from April 29, 2011) since it became unable to do sampling at ④.

0.038

ND

0.032

ND

0.027

ND

0.029

ND

ND

ND

ND

ND

ND

ND

ND

ND

* Sampling at ⑦ (located in the downstream of the groundwater) has been done since May 26, 2011.

ND

ND

* Samping at (8) since May 30, 2011

ND

ND

(8)

9

ND

ND

ND

ND

* Sampling at (9) has been done since August 2, 2011

ND

ND

* "ND" indicates that the measurement result is below the detection limit.

0.045

ND

I-131: Approx. 0.01Bq/cm³, Cs-134: Approx.0.02Bq/cm³, Cs-137: Approx.0.02Bq/cm³ (April 17, 2013)

ND 0.081

ND

ND

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

0.031

ND

0.064

ND

<Place of Sampling>

① Southeast of Unit 4 Turbine Building

② Northeast of the Process Main Building

3 Southeast of the Process Main Building

④ Southwest of the Process Main Building

(5) South Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building

Southwest Part of the On-site Bunker Building

⑦ West Side of the Incineration Workshop Building

8 North Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building

(9) Southeast Part of the On-site Bunker Building

Apr 18, 2013