

Nuclides Analysis Result of the Sub-drain Water in the Surroundings of the Central Radioactive Waste Treatment Facility

I-131(Bq/cm³)

| Sampling Location | Jul 14 | Jul 15 | Jul 16 | Jul 17 | Jul 18 | Jul 19 | Jul 20 | Jul 21 | Jul 22 | Jul 23 | Jul 24 | Jul 25 | Jul 26 | Jul 27 | Jul 28 | Jul 29 | Jul 30 | Jul 31 | Aug 1 | Aug 2 |
|-------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|-------|-------|
| ① | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| ② | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| ③ | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| ④ | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| ⑤ | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| ⑥ | - | ND | - | - | - | - | - | - | ND | - | - | - | - | - | - | ND | - | - | - | - |
| ⑦ | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| ⑧ | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| ⑨ | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |

Cs-134(Bq/cm³)

| Sampling Location | Jul 14 | Jul 15 | Jul 16 | Jul 17 | Jul 18 | Jul 19 | Jul 20 | Jul 21 | Jul 22 | Jul 23 | Jul 24 | Jul 25 | Jul 26 | Jul 27 | Jul 28 | Jul 29 | Jul 30 | Jul 31 | Aug 1 | Aug 2 |
|-------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|-------|-------|
| ① | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| ② | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| ③ | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| ④ | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| ⑤ | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| ⑥ | - | ND | - | - | - | - | - | - | ND | - | - | - | - | - | - | ND | - | - | - | - |
| ⑦ | 0.045 | 0.081 | 0.051 | 0.058 | 0.035 | 0.094 | 0.077 | 0.091 | 0.059 | 0.035 | 0.075 | 0.071 | 0.043 | 0.053 | 0.095 | 0.096 | 0.045 | 0.12 | 0.023 | 0.088 |
| ⑧ | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| ⑨ | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |

Cs-137(Bq/cm³)

| Sampling Location | Jul 14 | Jul 15 | Jul 16 | Jul 17 | Jul 18 | Jul 19 | Jul 20 | Jul 21 | Jul 22 | Jul 23 | Jul 24 | Jul 25 | Jul 26 | Jul 27 | Jul 28 | Jul 29 | Jul 30 | Jul 31 | Aug 1 | Aug 2 |
|-------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|-------|-------|
| ① | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| ② | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| ③ | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| ④ | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| ⑤ | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| ⑥ | - | ND | - | - | - | - | - | - | ND | - | - | - | - | - | - | ND | - | - | - | - |
| ⑦ | 0.11 | 0.19 | 0.12 | 0.13 | 0.099 | 0.2 | 0.16 | 0.24 | 0.13 | 0.072 | 0.15 | 0.15 | 0.083 | 0.13 | 0.22 | 0.24 | 0.13 | 0.19 | 0.08 | 0.21 |
| ⑧ | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |
| ⑨ | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND | ND |

* Hyphen "-" indicates that neither sampling nor measurement was implemented.
 * ⑥ was selected as a sampling location in the upstream of groundwater (sampling done once a week starting from April 29, 2011) since it became unable to do sampling at ④.
 * Sampling at ⑦ (located in the downstream of the groundwater) has been done since May 26, 2011.
 * Sampling at ⑧ since May 30, 2011
 * Sampling at ⑨ has been done since August 2, 2011
 * "ND" indicates that the measurement result is below the detection limit.

I-131: Approx. 0.01Bq/cm³, Cs-134: Approx.0.02Bq/cm³, Cs-137: Approx.0.02Bq/cm³ (August 2, 2013)
 As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

- <Place of Sampling>
 ① Southeast of Unit 4 Turbine Building
 ② Northeast of the Process Main Building
 ③ Southeast of the Process Main Building
 ④ Southwest of the Process Main Building
 ⑤ South Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building
 ⑥ Southwest Part of the On-site Bunker Building
 ⑦ West Side of the Incineration Workshop Building
 ⑧ North Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building
 ⑨ Southeast Part of the On-site Bunker Building