

Result of Pu Nuclide Analysis of Sub-Drain at Fukushima Daiichi Nuclear Power Station

1. Measurement Result:

(Unit: Bq/cm³)

Place of Sampling	Date	Pu-238	Pu-239+Pu-240
Unit 2 Sub-Drain	Mar 11, 2013	N.D. [$<5.4 \times 10^{-7}$]	N.D. [$<5.4 \times 10^{-7}$]
Deep Well	Mar 11, 2013	N.D. [$<5.1 \times 10^{-7}$]	N.D. [$<5.1 \times 10^{-7}$]

[] shows below the detection limit.

2. Analytical Institution

KAKEN Inc.

3. Evaluation:

Pu-238 and Pu-239+Pu-240 were not detected in the sample collected this time.

End