

Sampling Results Regarding the Water Leak at a Tank in the H5 area in Fukushima Daiichi Nuclear Power Station

Unit: Bq/cm³

	Leaking water at the bottom of the connection pipe between H5-IV-Tank No.5 and H5-IV-Tank No.6
Date of Sampling	Aug 31, 2013
Time of sampling	9:00 PM
Cs-134(Approx. 2 years)	25*
Cs-137(Approx.30 years)	61*
All β	3.0E+05

*1 Data announced this time is provided in a thick-frame. The other data was announced on September 1.

*2 0.OE+0 is the same as 0.Ox10⁺⁰.

* We initially announced that "analysis of γ nuclides could not be performed since the amount of sample necessary for analysis could not be obtained", but we have performed analysis by diluting the sample. Measurement results of diluted sample were multiplied by the dilution ratio to provide the amounts. We apologies for the mistake. (Corrected on September 4)