

Analysis Results of Accumulated Water at Unit 2 Seaside Trench in Fukushima Daiichi Nuclear Power Station

Unit: Bq/L (excludes chloride)

		Water intake power cable trench (seawater piping foundation part) (Unit 2 B1-1)
Date of sampling		Jul 26, 2013
Time of sampling		2:30 PM
Chloride (ppm)		8,000
Cs-134 (Approx. 2 years)		750,000,000
Cs-137 (Approx.30 years)		1,600,000,000
The other Y		
All β		750,000,000
H-3 (Approx. 12 years)		Under analysis

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* When the amount after filtration was ND, "-" will be stated at the comparison column.