

Nuclides Analysis Result of the Radioactive Materials in the Air at Fukushima Nuclear Power Stations

Reference

(Data summarized on September 25)

Place of Sampling	The West Gate of Fukushima Daiichi NPS						② Density Limit Specified by the Reactor Regulation (Bq/cm ³) (Density limit in the air which radiation workers breathe in is specified in section 4 of Appendix 2)
Time of Sampling	September 24, 2014 7:00 AM - 12:00 PM						
Detected Nuclides (Half-life)	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	
I-131 (Approx. 8 days)	ND	-					1E-03
Cs-134 (Approx. 2 years)	ND	-					2E-03
Cs-137 (Approx. 30 years)	ND	-					3E-03

* The radioactivity density is the sum of the volatile nuclides density and the particulate nuclides density.

O.OE—O is the same as $O.O \times 10^{-O}$

Data of other nuclides is under examination.

* In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

* "ND indicates that the measurement result is below the detection limit value.

The detection limit values are as follows:

Volatile, I-131: Approx. $9E-8Bq/cm^3$, Cs-134: Approx. $2E-7Bq/cm^3$, Cs-137: Approx. $2E-7Bq/cm^3$

Particulate, I-131: Approx. $7E-8Bq/cm^3$, Cs-134: Approx. $6E-8Bq/cm^3$, Cs-137: Approx. $6E-8Bq/cm^3$

As the detection limit value may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit value are detected.

Analysis Result of Sr in the Air at Fukushima Daiichi Nuclear Power Station <1/2>

1 Results

(Data summarized on September 25)
(Unit: Bq/cm³)

Place of Sampling	Type	Date of Sampling	Sr-89	Sr-90
The West Gate of Fukushima Daiichi NPS	Volatile	Jul 15, 2013	N.D.	N.D.
	Particulate		N.D.	N.D.

2 Evaluation

Neither Sr-89 or Sr-90 were not detected in the sample.

Ends

Analysis Result of Sr in the Air at Fukushima Daiichi Nuclear Power Station <2/2>

1 Results

(Data summarized on September 25)
(Unit: Bq/cm³)

Place of Sampling	Type	Date of Sampling	Sr-89	Sr-90
The West Gate of Fukushima Daiichi NPS	Volatile	Aug 12, 2013	N.D.	N.D.
	Particulate		N.D.	N.D.

2 Evaluate

Neither Sr-89 or Sr-90 were not detected in the sample.

Ends

Dust Nuclides Analysis Result: The West Gate of Fukushima Daiichi Nuclear Power Station (Bq/cm³)

