Nuclides Analysis Result of the Radioactive Materials in the Air at Fukushima Nuclear Power Stations | Re

Reference

Place of Sampling	The West Gate of Fukushima Daiichi NPS						<ul> <li>② Density Limit Specified by the Reactor Regulation</li> <li>(Bq/cm^3) (Density limit in the air which radiation workers breathe in is specified in</li> </ul>
Time of Sampling	November 10, 2014 7:00 AM - 12:00 PM						
Detected Nuclides (Half- life)	①Density of Sample (Bq/cm^3)	Scaling Factor (①/②)	①Density of Sample (Bq/cm^3)	Scaling Factor (①/②)	①Density of Sample (Bq/cm^3)	Scaling Factor (①/②)	section 4 of Appendix 2)
I-131 (Approx. 8 days)	ND	-					1E-03
Cs-134 (Approx. 2 years)	ND	-					2E-03
Cs-137 (Approx. 30 years)	ND	-					3E-03

(Data summarized on November 11)

\* The radioactivity density is the sum of the volatile nuclides density and the particulate nuclides density.

O.OE-O is the same as  $O.O \times 10^{-O}$ 

Data of other nuclides is under examination.

\* In the case of 2 nuclides or more, the sum of scaling factors to density limits is compared to 1.

\* "ND" indicates that the measurement result is below the detection limit.

The detection limits at the west gate of Fukushima Daiichi NPS are as follows: Volatile: I-131: Approx. 1E-7Bq/cm^3, Cs-134: Approx.1E-7Bq/cm^3, Cs-137: Approx.1E-7Bq/cm^3 Particulate: I-131: Approx. 7E-8Bq/cm^3, Cs-134: Approx.1E-7Bq/cm^3, Cs-137: Approx.7E-8Bq/cm^3 As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

Dust Nuclides Analysis Result: The West Gate of Fukushima Daiichi Nuclear Power Station (Bq/cm^3)

