

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

<Reference>
February 20, 2014
Tokyo Electric Power Company

Unit: Bq/L

	Groundwater around H4 area													
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8	E-9	E-10	E-11	E-12	Well point	F-1
Date of Sampling	Feb 19, 2014	Feb 19, 2014	Feb 19, 2014	Feb 19, 2014	Feb 19, 2014	Feb 19, 2014	Feb 19, 2014	Feb 19, 2014	Feb 19, 2014	Feb 19, 2014	/	/	/	/
Time of sampling	9:33 AM	9:27 AM	9:20 AM	9:14 AM	9:08 AM	9:56 AM	9:00 AM	8:55 AM	9:41 AM	/	/	/	/	/
Gross β	69,000	ND(18)	ND(18)	ND(18)	ND(18)	ND(18)	ND(18)	ND(18)	6,100 ^{*1}	/	/	/	/	/
H-3 (Approx. 12 years)	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	Under analysis	/	/	/	/	/

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

*1 The highest dose among the results previously announced in the "Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)".

<Reference> The Highest Dose Until the Previous Measurement

	E-1	E-2	E-3	E-4	E-5	E-6	E-7
Gross β	710,000 [11/10]	650 [9/4]	570 [9/18]	1,300 [9/15]	100 [9/24]	46 [9/20]	21 <1/22>
H-3 (Approx. 12 years)	790,000 [10/17]	530 [10/5] <1/3>	2,800 <1/17>	2,600<2/18>	3,100 [11/10,11/13]	350 [12/18] <1/1>	840 [10/9]

	E-8	E-9	E-10	E-11	E-12	Well point	F-1
Gross β	17 [10/3]	730 [12/27]	29 <1/30>	110<2/5>	37 <1/23>	16,000 [11/28]	24 <1/31>
H-3 (Approx. 12 years)	2,300 [11/13]	51,000 [11/25]	54,000 <1/21>	1,000<2/12>	2,900 <2/12>	190,000 [11/30]	720 [12/31]

Unit: Bq/L, sampling date is provided in parentheses.
[]: 2013, < >: 2014

