

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Around the H4 Area)

<Reference>
February 24, 2014
Tokyo Electric Power Company

Unit: Bq/L

	Groundwater around H4 area													Well point	F-1
	E-1	E-2	E-3	E-4	E-5	E-6	E-7	E-8	E-9	E-10	E-11	E-12			
Date of Sampling	Feb 22, 2014	Feb 22, 2014	Feb 22, 2014	Feb 22, 2014	Feb 22, 2014	/	/	/	/	Feb 22, 2014	/	/	/		
Time of sampling	9:25 AM	9:20 AM	9:05 AM	8:58 AM	8:48 AM	/	/	/	/	9:10 AM	/	/	/		
Gross β	23,000	ND(18)	ND(18)	32	ND(18)	/	/	/	/	25	/	/	/		
H-3 (Approx. 12 years)	23,000	350	1,200	2,200	1,400	/	/	/	/	7,000	/	/	/		

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement

	E-1	E-2	E-3	E-4	E-5	E-6	E-7
Gross β	710,000 [11/10]	650 [9/4]	570 [9/18]	1,300 [9/15]	100 [9/24]	46 [9/20]	21 <1/22>
H-3 (Approx. 12 years)	790,000 [10/17]	530 [10/5] <1/3>	2,800 <1/17>	2,600 <2/18>	3,100 [11/10,11/13]	350 [12/18] <1/1>	1,100 <2/19>

	E-8	E-9	E-10	E-11	E-12	Well point	F-1
Gross β	17 [10/3]	6,100 <2/19>	29 <1/30>	110 <2/5>	37 <1/23>	16,000 [11/28]	24 <1/31>
H-3 (Approx. 12 years)	2,300 [11/13]	51,000 [11/25]	54,000 <1/21>	1,000 <2/12>	2,900 <2/12>	190,000 [11/30]	720 [12/31]

Unit: Bq/L, sampling date is provided in parentheses.
[]: 2013, < >: 2014

