

**Tritium Analysis Results of the Underground Bypass (Investigation Holes/Pumping Well) and the Sea Side Observation Holes  
(As of March 17 and 18, 2014)**

	Underground bypass investigation holes			Underground bypass pumping well				Sea side observation holes							
	a	b	c	1	2	3	4	①	②	③	④	⑤	⑥	⑦	⑧
	Mar 18, 2014										Mar 17, 2014				
Sampled time		10:37 AM	10:04 AM	10:14 AM	10:18 AM	10:21 AM	10:23 AM	11:13 AM	11:44 AM	9:30 AM	12:14 PM	9:36 AM	10:25 AM	10:05 AM	11:00 AM
Chloride concentration (ppm)		9	12	16	21	82	9	10	9	8	13	9	10	15	9
Tritium (Bq/cm <sup>3</sup> )		2.4E-1	<8.6E-3	1.5E-2	4.9E-2	1.2E-2	9.3E-2	8.6E-2	3.0E-2	6.5E-1	2.6E+0	6.9E-2	7.4E-2	3.7E-2	9.3E-2
All β(Bq/cm <sup>3</sup> )		<2.8E-2	<2.8E-2	<1.5E-2	<1.5E-2	<1.5E-2	<1.5E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2

Half-life period Tritium: Approx. 12 years

(Note 1) Nuclide analysis results other than tritium were announced on March 18 and 19.

(Note 2) O.OE±O is the same as O.O x 10<sup>±0</sup>.

(Note 3) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.