

## Underground Reservoir Nuclide Analysis Results (As of June 24, 2014)

|  |  | Underground Reservoir (Drain hole water) |                |                |                |                |                |                |                |                |                |                |                |                |                |
|--|--|--|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|
|  |  | i  |                | ii             |                | iii            |                | iv             |                | v              |                | vi             |                | vii            |                |
|  |  | Northeast side                           | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side |
| Sampled time                                       |  | 7:33 AM                                  |                | 7:36 AM        |                | 7:39 AM        | 7:45 AM        |                |                |                |                |                |                |                |                |
| Chloride concentration (ppm)                       |  | 8  |                | 8              |                | 5              | 2              |                |                |                |                |                |                |                |                |
| Radioactive concentration<br>(Bq/cm <sup>3</sup> ) | I-131                                      | <2.3E-2                                  |                | <2.7E-2        |                | <2.2E-2        | <2.3E-2        |                |                |                |                |                |                |                |                |
|  | Cs-134                                     | <4.5E-2                                  |                | <4.4E-2        |                | <3.7E-2        | <4.3E-2        |                |                |                |                |                |                |                |                |
|  | Cs-137                                     | <5.6E-2                                  |                | <6.3E-2        |                | <5.8E-2        | <6.4E-2        |                |                |                |                |                |                |                |                |
|  | γ nuclides other than the major 3 nuclides | ND                                       |                | ND             |                | ND             | ND             |                |                |                |                |                |                |                |                |
|  | All β                                      | 2.0E-1                                   |                | <3.0E-2        |                | 3.3E-2         | 3.2E-2         |                |                |                |                |                |                |                |                |

Half-life period I-131: Approx. 8 days, Cs-134: Approx. 2 years, Cs-137: Approx. 30 years

|  |  | Underground Reservoir (Leakage detector hole water) |                |                |                |                |                |                |                |                |                |                |                |                |                |
|--|--|---|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|
|  |  | i   |                | ii             |                | iii            |                | iv             |                | v              |                | vi             |                | vii            |                |
|  |  | Northeast side                                      | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side | Northeast side | Southwest side |
| Sampled time                                       |  | 7:30 AM   |                | 7:26 AM        |                | 7:48 AM        | 7:42 AM        |                |                |                |                |                |                |                |                |
| Chloride concentration (ppm)                       |  | 10  |                | 14             |                | 8              | 9              |                |                |                |                |                |                |                |                |
| Radioactive concentration<br>(Bq/cm <sup>3</sup> ) | I-131                                      | <2.4E-2   |                | <2.9E-2        |                | <2.5E-2        | <2.5E-2        |                |                |                |                |                |                |                |                |
|  | Cs-134                                     | <3.9E-2   |                | <4.8E-2        |                | <3.9E-2        | <4.1E-2        |                |                |                |                |                |                |                |                |
|  | Cs-137                                     | <5.9E-2   |                | <6.5E-2        |                | <5.8E-2        | <6.4E-2        |                |                |                |                |                |                |                |                |
|  | γ nuclides other than the major 3 nuclides | ND  |                | ND             |                | ND             | ND             |                |                |                |                |                |                |                |                |
|  | All β                                      | 5.6E+1  |                | 1.9E+1         |                | 2.0E+1         | 8.7E+0         |                |                |                |                |                |                |                |                |

Half-life period I-131: Approx. 8 days, Cs-134: Approx. 2 years, Cs-137: Approx. 30 years

(Note 1) O.OE±O is the same as O.O x 10<sup>±0</sup>.

(Note 2) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.

(Note 3) "ND" indicates that the measurement result of γ nuclides other than the major 3 nuclides are below the detection limit.

**Nuclide Analysis Results of the Underground Bypass (Investigation Holes/Pumping Well) and the Sea Side Observation Holes  
(As of June 24, 2014)**

|                               | Underground bypass investigation holes |                |                | Sea side observation holes |                |                |                |   |   |   |   |
|-------------------------------|--|----------------|----------------|----------------------------|----------------|----------------|----------------|---|---|---|---|
|                               | a                                      | b              | c              | ①                          | ②              | ③              | ④              | ⑤ | ⑥ | ⑦ | ⑧ |
| Sampled time                  | /                                      | 9:50 AM        | 9:33 AM        | 10:26 AM                   | 10:51 AM       | 9:07 AM        | 10:11 AM       | / | / | / | / |
| Chloride concentration (ppm)  | /                                      | 8              | 13             | 9                          | 7              | 9              | 12             | / | / | / | / |
| Tritium (Bq/cm <sup>3</sup> ) | /                                      | Under analysis | Under analysis | Under analysis             | Under analysis | Under analysis | Under analysis | / | / | / | / |
| All β(Bq/cm <sup>3</sup> )    | /                                      | <3.0E-2        | <3.0E-2        | <3.0E-2                    | <3.0E-2        | <3.0E-2        | <3.0E-2        | / | / | / | / |

Half-life period of tritium: Approx. 12 years

(Note 1) 0.0E±0 is the same as 0.0 x 10<sup>±0</sup>.

(Note 2) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.