

**Tritium Analysis Results of the Underground Bypass (Investigation Holes/Pumping Well) and the Sea Side Observation Holes
(As of August 25 and 26, 2014)**

	Underground bypass investigation holes			Sea side observation holes							
	a	b	c	①	②	③	④	⑤	⑥	⑦	⑧
	Aug 26, 2014							Aug 25, 2014			
Sampled time		7:20 AM	6:48 AM	8:04 AM	8:23 AM	6:24 AM	7:40 AM	6:54 AM	6:33 AM	7:15 AM	6:13 AM
Chloride concentration (ppm)		7	11	5	5	8	12	6	9	11	11
Tritium (Bq/cm ³)		1.2E-1	<9.1E-3	3.4E-2	4.4E-2	2.8E-1	1.3E+0	3.9E-2	1.1E-1	4.4E-2	1.4E-1
All β(Bq/cm ³)		<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2

Half-life period Tritium: Approx. 12 years

(Note 1) Nuclide analysis results other than tritium were announced on August 26 and 27.

(Note 2) O.OE±O is the same as O.O x 10^{±0}.

(Note 3) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.