

**Tritium Analysis Results of the Underground Bypass (Investigation Holes/Pumping Well) and the Sea Side Observation Holes
(As of November 17 and 18, 2014)**

	Underground bypass investigation holes			Sea side observation holes							
	a	b	c	①	②	③	④	⑤	⑥	⑦	⑧
	Nov 18, 2014							Nov 17, 2014			
Sampled time		8:34 AM	8:16 AM	9:11 AM	9:29 AM	7:54 AM	8:53 AM	8:36 AM	8:15 AM	8:53 AM	7:57 AM
Chloride concentration (ppm)		9	11	6	6	8	13	6	9	12	12
All β(Bq/cm ³)		<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2
Tritium (Bq/cm ³)		9.7E-2	<7.6E-3	3.4E-2	4.3E-2	2.4E-1	1.0E+0	3.1E-2	1.0E-1	3.4E-2	1.6E-1

Half-life period Tritium: Approx. 12 years

(Note 1) Nuclide analysis results other than tritium were announced November 18 and 19

(Note 2) 0.0E±0 is the same as 0.0 x 10^{±0}.

(Note 3) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.