

**Tritium Analysis Results of the Underground Bypass (Investigation Holes/Pumping Well) and the Sea Side Observation Holes
(As of November 24 and 25, 2014)**

	Underground bypass investigation holes			Sea side observation holes								
	a	b	c	①	②	③	④	⑤	⑥	⑦	⑧	
	Nov 25, 2014							Nov 24, 2014				
Sampled time		8:51 AM	8:30 AM	9:40 AM	9:57 AM	8:00 AM	9:12 AM	8:39 AM	8:17 AM	8:55 AM	7:51 AM	
Chloride concentration (ppm)		8	12	6	6	7	12	6	9	11	10	
All β (Bq/cm ³)		<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<3.0E-2	<2.8E-2	<2.8E-2	<2.8E-2	<2.8E-2	
Tritium (Bq/cm ³)		9.2E-2	<8.3E-3	2.7E-2	3.2E-2	2.6E-1	1.1E+0	3.6E-2	1.0E-1	3.8E-2	1.6E-1	

Half-life period Tritium: Approx. 12 years

(Note 1) Nuclide analysis results other than tritium were announced October 25 and 26.

(Note 2) 0.0E±0 is the same as 0.0 x 10^{±0}.

(Note 3) The figures written next to "<" indicate the detection limit when the measurement result is below the detection limit.