

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Pump Well)

<Reference>
 January 2, 2014
 Tokyo Electric Power Company

Unit: Bq/L

	Pump wells of the groundwater bypass							
	No.5	No.6	No.7	No.8	No.9	No.10	No.11	No.12
Date of Sampling	Dec 31, 2013	Dec 31, 2014	Dec 31, 2014	Dec 31, 2014	Dec 31, 2014	Dec 31, 2014	Dec 31, 2014	Dec 31, 2014
Time of sampling	11:11 AM	11:16 AM	11:23 AM	11:26 AM	11:30 AM	11:33 AM	11:41 AM	11:44 AM
All β	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)
H-3 (Approx. 12 years)	30	140	510	67	81	170	290	870

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement

	No.5	No.6	No.7	No.8
All β	ND	ND	ND	ND
H-3 (Approx. 12 years)	41 [11/5]	160 [10/22]	620 [11/19]	97 [11/26]

	No.9	No.10	No.11	No.12
All β	ND	ND	ND	ND
H-3 (Approx. 12 years)	100 [11/26,12/3]	330 [9/1,9/2]	480 [10/22,11/5]	1,000 [12/24]

Unit: Bq/L, sampling date is provided in parentheses.

