

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Pump Well)

<Reference>
January 23, 2014
Tokyo Electric Power Company

Unit: Bq/L

	Pump wells of the groundwater bypass							
	No.5	No.6	No.7	No.8	No.9	No.10	No.11	No.12
Date of Sampling	Jan 21, 2014	Jan 21, 2014	Jan 21, 2014	Jan 21, 2014	Jan 21, 2014	Jan 21, 2014	Jan 21, 2014	Jan 21, 2014
Time of sampling	9:49 AM	9:53 AM	9:57 AM	10:00 AM	10:04 AM	10:06 AM	10:15 AM	10:18 AM
All β	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)	ND(15)
H-3 (Approx. 12 years)	23	160	560	70	80	200	340	980

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement

	No.5	No.6	No.7	No.8
All β	ND	ND	ND	ND
H-3 (Approx. 12 years)	41 [11/5]	170 <1/14>	620 [11/19]	97 [11/26]

	No.9	No.10	No.11	No.12
All β	ND	ND	ND	ND
H-3 (Approx. 12 years)	100 [11/26,12/3]	330 [9/1,9/2]	480 [10/22,11/5]	1,000 [12/24]

Unit: Bq/L, sampling date is provided in parentheses.
[]: 2013, < >: 2014

