

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Pump Well)

<Reference>
February 14, 2014
Tokyo Electric Power Company

Unit: Bq/L

	Pump wells of the groundwater bypass							
	No.5	No.6	No.7	No.8	No.9	No.10	No.11	No.12
Date of Sampling	Feb 11, 2014	Feb 11, 2014	Feb 11, 2014	Feb 11, 2014	Feb 11, 2014	Feb 11, 2014	Feb 11, 2014	Feb 11, 2014
Time of sampling	10:35 AM	10:40 AM	10:44 AM	10:49 AM	10:52 AM	10:56 AM	11:13 AM	11:17 AM
All β	ND(14)	ND(14)	ND(14)	ND(14)	ND(14)	ND(14)	ND(14)	ND(14)
H-3 (Approx. 12 years)	21	140	590	57	84	180	290	1,100*1

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

*1 The highest dose among the results previously announced in the "Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Pump Well)".

<Reference> The Highest Dose Until the Previous Measurement

	No.5	No.6	No.7	No.8
All β	ND	ND	ND	ND
H-3 (Approx. 12 years)	41 [11/5]	170 <1/14>	620 [11/19]	97 [11/26]

	No.9	No.10	No.11	No.12
All β	ND	ND	ND	ND
H-3 (Approx. 12 years)	100 [11/26,12/3]	330 [9/1,9/2]	480 [10/22,11/5]	1,000 [12/24]

Unit: Bq/L, sampling date is provided in parentheses.
[]: 2013, < >: 2014

