

Sampling Results Regarding the Influence on the Water Leak at a Tank in the H4 area in Fukushima Daiichi Nuclear Power Station (Pump Well)

<Reference>
February 20, 2014
Tokyo Electric Power Company

Unit: Bq/L

	Pump wells of the groundwater bypass							
	No.5	No.6	No.7	No.8	No.9	No.10	No.11	No.12
Date of Sampling	Feb 18, 2014	Feb 18, 2014	Feb 18, 2014	Feb 18, 2014	Feb 18, 2014	Feb 18, 2014	Feb 18, 2014	Feb 18, 2014
Time of sampling	10:47 AM	10:50 AM	10:54 AM	10:58 AM	11:01 AM	11:04 AM	11:14 AM	11:17 AM
All β	ND(16)	ND(16)	ND(16)	ND(16)	ND(16)	ND(16)	ND(16)	ND(16)
H-3 (Approx. 12 years)	26	140	560	68	75	190	310	1100

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement

	No.5	No.6	No.7	No.8
All β	ND	ND	ND	ND
H-3 (Approx. 12 years)	41 [11/5]	170 <1/14>	620 [11/19]	97 [11/26]

	No.9	No.10	No.11	No.12
All β	ND	ND	ND	ND
H-3 (Approx. 12 years)	100 [11/26,12/3]	330 [9/1,9/2]	480 [10/22,11/5]	1,100 <2/11>

Unit: Bq/L, sampling date is provided in parentheses.
[]: 2013, <>: 2014

