

Analysis Results of Rainwater Obtained Inside the Dike at the Tank Area After Treated by the Rainwater Treatment System

<Desalination RO membrane system>

	Radioactive density [Bq/L]		Sampling place	Sampling date	Sampling time
	Chemical Analysis Building *	Laboratory at Unit 5 and 6			
Cs-134	ND (6.8E-01)	ND (5.1E-01)	Treated water tank	May 28, 2014	4:00 PM
Cs-137	ND (6.8E-01)	ND (6.5E-01)			
Gross β	ND (9.2E-01)	1.6E+00			
Tritium	1.2E+02	ND (1.1E+02)	Receiving tank	May 27, 2014	11:00 AM
Notification density rate	0.052	0.070			

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* Analysis of tritium is performed at Environment Management Building.