

Radioactive Material Density in the Air at the Place Where Rainwater Obtained Inside the Dike at the Tank Area After Treated by the Rainwater Treatment System is Sprinkled and Ambient Dose Rate at the Surrounding Area (Sampled and Measured on May 29, 2014)

(Data summarized on May 30)

Measurement item	Measurement result [ Bq/cm <sup>3</sup> ]	Measurement date
Radioactive material density in the air (Particle)	Cs-134	ND (2.7E-6)
	Cs-137	ND (4.0E-6)
	Cs-134	ND (2.7E-6)
	Cs-137	ND (3.9E-6)
		May 29, 2014 10:10 AM ~ 10:20 AM *1
		May 29, 2014 3:20 PM ~ 3:30 PM *2

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

Measurement item	Measurement result [ mSv/h ]	Measurement date
Ambient dose rate	0.009	May 29, 2014 10:11 AM *1
	0.009	May 29, 2014 3:22 PM *2

\*1 The sampling and measurement was performed before sprinkling treated water.

\*2 The sampling and measurement was performed during sprinkling treated water.

Ends