

## Analysis Results of Rainwater Obtained Inside the Dike at the Tank Area After Treated by the Rainwater Treatment System

### <Mobile RO membrane system>

	Measurement result [Bq/L]		Sampling place	Sampling date	Sampling time
	Chemical Analysis Building *	Laboratory at Unit 5 and 6			
Cs-134	ND ( 5.9E-01 )	ND ( 7.1E-01 )	Treated water tank	Oct 8, 2014	4:40 PM
Cs-137	ND ( 5.3E-01 )	ND ( 7.3E-01 )			
Gross $\beta$	ND ( 8.8E-01 )	ND ( 9.7E-01 )			
Tritium	7.9E+02	7.0E+02	Receiving tank	Oct 6, 2014	4:00 PM
Notification density rate*	0.058	0.064			

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

\* Analysis of tritium is performed at Environment Management Building.