

Analysis Results of Rainwater Obtained Inside the Dike at the Tank Area After Treated by the Rainwater Treatment System

<Mobile RO membrane system>

	Measurement result [Bq/L]		Sampling place	Sampling date	Sampling time
	Chemical Analysis Building *	Laboratory at Unit 5 and 6			
Cs-134	ND (5.9E-01)	ND (6.1E-01)	Treated water tank	Oct 15, 2014	4:40 PM
Cs-137	ND (6.3E-01)	ND (7.8E-01)			
Gross β	ND (4.0E+00)	ND (4.5E+00)			
Tritium	4.9E+02	4.5E+02	Receiving tank	Oct 13, 2014	5:00 PM
Notification density rate*	0.16	0.18			

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* Analysis of tritium is performed at Environment Management Building.