

Analysis Results of Rainwater Obtained Inside the Dike at the Tank Area After Treated by the Rainwater Treatment System

<Mobile RO membrane system>

| | Measurement result [Bq/L] | | Sampling place | Sampling date | Sampling time |
|----------------------------|------------------------------|----------------------------|--------------------|---------------|---------------|
| | Chemical Analysis Building * | Laboratory at Unit 5 and 6 | | | |
| Cs-134 | ND (7.6E-01) | | Treated water tank | Oct 25, 2014 | 4:00 PM |
| Cs-137 | ND (6.3E-01) | | | | |
| Gross β | ND (4.0E+00) | | | | |
| Tritium | 2.3E+02 | | Receiving tank | Oct 23, 2014 | 1:20 PM |
| Notification density rate* | 0.157 | | | | |

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* Analysis of tritium is performed at Environment Management Building.