

<Reference>

April 17, 2014

Tokyo Electric Power Company

Sampling Results of Sub-drain Water Regarding Wrong Transfer of Accumulated Water to the Incineration Workshop Building

	West side of the Incineration Workshop Building					
	Apr 17, 2014					
	(1) 4:00 AM	(2) 8:00 AM	(3) 12:00 PM	(4) 4:00 PM	(5) 8:00 PM	(6) 12:00 AM
Time of sampling	4:00 AM	8:00 AM				
Gross β (Bq/cm ³)	0.11	0.12				
Tritium (Bq/cm ³)	Under analysis	Under analysis				

Half-life of tritium: Approx 12 years

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

