

Sampling Results of Sub-drain Water Regarding Wrong Transfer of Accumulated Water to the Incineration Workshop Building

| | East side of the Incineration Workshop Building | |
|-------------------------------------|---|----------------|
| Date of sampling | Jun 10, 2014 | Jun 11, 2014 |
| Time of sampling | 8:06 AM | 8:09 AM |
| Gross β (Bq/cm ³) | 0.059 | 0.034 |
| Tritium (Bq/cm ³) | ND(0.11) | Under analysis |

Half-life of tritium: Approx 12 years

* Data announced this time is provided in a thick-frame. The other data was announced on June 10.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

