


Nuclides Analysis Result of the Radioactive Materials in the Seawater < Coast, Fukushima Daiichi Nuclear Power Station >

(Data summarized on October 1)

Place of Sampling	North of Unit 5-6 Discharge Channel at Fukushima Daiichi NPS (Approx. 30m North of Unit 5-6 Discharge Channel)	Around South Discharge Channel of Fukushima Daiichi NPS (Approx. 1.3km South of Unit 1-4 Discharge Channel)			
Time of Sampling	Sep 30, 2014 Not sampled	Sep 30, 2014 Not sampled		② Density Limit Specified by the Reactor Regulation (Bq/L) (The density limit in the water outside the surrounding monitored areas is provided in section 6 of Appendix 2.)	
Detected Nuclides (Half-life)	①Density of Sample (Bq/L)	Scaling Factor (①/②)	①Density of Sample (Bq/L)		Scaling Factor (①/②)
I-131 (Approx. 8 days)	-	-	-	-	40
Cs-134 (Approx. 2 years)	-	-	-	-	60
Cs-137 (Approx. 30 years)	-	-	-	-	90

- * The density specified by the Reactor Regulation is converted from Bq/cm³ to Bq/L.
- * Data of other nuclides is under evaluation.
- * In the case of 2 nuclides or more, the sum of scaling factors to density limits is compared to 1.
- * "ND" indicates that the measurement result is below the detection limit, which is provided in parentheses.
- * Not sampled because of bad weather.

Radioactivity Density of the Seawater at 1F Units 5-6 North Discharge Channel (Bq/L)



Radioactivity Density of the Seawater at 1F Units 5-6 North Discharge Channel (Bq/L)

