Nuclides Analysis Result of the Sub-drain Water in the Surroundings of the Central Radioactive Waste Treatment Facility

I-131(Bq/cm³)

Sampling																			
Location	Apr 27	Apr 28	Apr 29	Apr 30	May 01	May 02	May 03	May 04	May 05	May 06	May 07	May 08	May 09	May 10	May 11	May 12	May 13		
1	ND																		
2	ND																		
3	ND																		
4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
⑤	ND																		
6	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND	-		
7	ND																		
8	ND																		
9	ND																		

Cs-134(Bq/cm³)

Sampling																				
Location	Apr 27	Apr 28	Apr 29	Apr 30	May 01	May 02	May 03	May 04	May 05	May 06	May 07	May 08	May 09	May 10	May 11	May 12	May 13			
1	ND																			
2	ND																			
3	ND																			
4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
⑤	ND																			
6	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND	-			
7	0.029	0.038	0.027	0.025	0.029	0.03	0.027	0.031	0.033	0.028	0.027	0.02	0.033	0.056	0.024	0.042	0.019			
8	ND	ND	ND	ND	ND	ND	0.03	0.021	ND											
9	ND																			

Cs-137(Bq/cm³)

Sampling																			
Location	Apr 27	Apr 28	Apr 29	Apr 30	May 01	May 02	May 03	May 04	May 05	May 06	May 07	May 08	May 09	May 10	May 11	May 12	May 13		
1	ND	ND	ND	0.041	ND	0.033	ND												
2	ND																		
3	ND																		
4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
5	ND																		
6	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND	-		
7	0.082	0.1	0.092	0.1	0.12	0.064	0.084	0.079	0.097	0.056	0.076	0.05	0.093	0.13	0.069	0.1	0.071		
8	ND	ND	ND	ND	ND	ND	0.06	0.074	ND										
9	ND																		

- * Hyphen "-" indicates that neither sampling nor measurement was implemented.
- * 6 was selected as a sampling location in the upstream of groundwater (sampling done once a week starting from April 29, 2011) since it became unable to do sampling at 4.
- * Sampling at ⑦ (located in the downstream of the groundwater) has been done since May 26, 2011.
- * Samping at ® since May 30, 2011
- * Sampling at 9 has been done since August 2, 2011
- * "ND" indicates that the measurement result is below the detection limit.

I-131: Approx. 0.008Bq/cm³, Cs-134: Approx. 0.01Bq/cm³, Cs-137: Approx. 0.02Bq/cm³ (May 13, 2014)

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

<Place of Sampling>

- 1) Southeast of Unit 4 Turbine Building
- 2 Northeast of the Process Main Building
- 3 Southeast of the Process Main Building
- 4 Southwest of the Process Main Building
- ⑤ South Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building
- 6 Southwest Part of the On-site Bunker Building
- (7) West Side of the Incineration Workshop Building
- ® North Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building
- Southeast Part of the On-site Bunker Building