Nuclides Analysis Result of the Sub-drain Water in the Surroundings of the Central Radioactive Waste Treatment Facility

I-131(Bq/cm³)

Sampling																			
Location	Jun 01	Jun 02	Jun 03	Jun 04	Jun 05	Jun 06	Jun 07	Jun 08	Jun 09	Jun 10	Jun 11	Jun 12	Jun 13	Jun 14	Jun 15	Jun 16	Jun 17		
1	ND																		
2	ND																		
3	ND																		
4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
(5)	ND																		
6	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND	-		
7	ND																		
8	ND																		
9	ND																		

Cs-134(Bq/cm³)

Sampling																				
Location	Jun 01	Jun 02	Jun 03	Jun 04	Jun 05	Jun 06	Jun 07	Jun 08	Jun 09	Jun 10	Jun 11	Jun 12	Jun 13	Jun 14	Jun 15	Jun 16	Jun 17			
1	ND																			
2	ND																			
3	ND																			
4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-			
5	ND																			
6	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	ND	-			
7	0.025	0.033	0.022	0.015	0.013	0.017	0.021	0.024	0.042	0.045	0.041	0.024	0.031	0.032	0.028	0.034	0.03			
8	ND	0.17	0.062	0.11	0.069	0.055	0.054	0.07	0.044											
9	ND																			

Cs-137(Bq/cm³)

Sampling																			
Location	Jun 01	Jun 02	Jun 03	Jun 04	Jun 05	Jun 06	Jun 07	Jun 08	Jun 09	Jun 10	Jun 11	Jun 12	Jun 13	Jun 14	Jun 15	Jun 16	Jun 17		
1	ND																		
2	ND																		
3	ND																		
4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
5	ND																		
6	-	ND	-	-	-	-	-	-	ND	-	-	-	-	-	-	0.046	-		
7	0.057	0.064	0.071	0.055	0.06	0.045	0.049	0.072	0.13	0.13	0.076	0.083	0.083	0.086	0.068	0.085	0.084		
8	ND	0.46	0.17	0.29	0.23	0.17	0.14	0.16	0.13										
9	ND																		

- * Hyphen "-" indicates that neither sampling nor measurement was implemented.
- * 6 was selected as a sampling location in the upstream of groundwater (sampling done once a week starting from April 29, 2011) since it became unable to do sampling at 4.
- * Sampling at ⑦ (located in the downstream of the groundwater) has been done since May 26, 2011.
- * Samping at ® since May 30, 2011
- * Sampling at (9) has been done since August 2, 2011
- * "ND" indicates that the measurement result is below the detection limit.

I-131: Approx. 0.009Bq/cm³, Cs-134: Approx. 0.01Bq/cm³, Cs-137: Approx. 0.02Bq/cm³ (June 17, 2014)

As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

<Place of Sampling>

- ① Southeast of Unit 4 Turbine Building
- 2 Northeast of the Process Main Building
- 3 Southeast of the Process Main Building
- 4 Southwest of the Process Main Building
- ⑤ South Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building
- 6 Southwest Part of the On-site Bunker Building
- (7) West Side of the Incineration Workshop Building
- 8 North Part of the Miscellaneous Solid Waste Volume Reduction Treatment Building
- 9 Southeast Part of the On-site Bunker Building