

Result of Pu Nuclide Analysis of Sub-Drain at Fukushima Daiichi Nuclear Power Station <1/2>

1. Measurement Result:

(Data summarized on March 28)

(Unit: Bq/cm³)

Place of Sampling	Date	Pu-238	Pu-239+Pu-240
Unit 2 Sub-Drain	Aug 16, 2013	N.D. [4.5×10^{-7}]	N.D. [4.9×10^{-7}]
Unit 6 Sub-Drain	Aug 16, 2013	N.D. [6.5×10^{-7}]	N.D. [6.5×10^{-7}]

[] shows below the detection limit.

2. Analytical Institution

KAKEN Inc.

3. Evaluation:

Pu-238 and Pu-239+Pu-240 were not detected in the sample collected this time.

End

Result of Pu Nuclide Analysis of Sub-Drain at Fukushima Daiichi Nuclear Power Station <2/2>

1. Measurement Result:

(Data summarized on March 28)

(Unit: Bq/cm³)

Place of Sampling	Date	Pu-238	Pu-239+Pu-240
Unit 2 Sub-Drain	Sep 9, 2013	N.D. [4.5×10^{-7}]	N.D. [5.0×10^{-7}]
Deep well	Sep 9, 2013	N.D. [6.1×10^{-7}]	N.D. [6.1×10^{-7}]

[] shows below the detection limit.

2. Analytical Institution

KAKEN Inc.

3. Evaluation:

Pu-238 and Pu-239+Pu-240 were not detected in the sample collected this time.

End