

Result of Pu Nuclide Analysis of Sub-Drain at Fukushima Daiichi Nuclear Power Station <1/2>

1. Measurement Result:

(Data summarized on June 27)

(Unit: Bq/cm<sup>3</sup>)

Place of Sampling	Date	Pu-238	Pu-239+Pu-240
Unit 2 Sub-Drain	Jan 10, 2014	N.D. [ $5.8 \times 10^{-7}$ ]	N.D. [ $5.8 \times 10^{-7}$ ]
Unit 5 Sub-Drain	Jan 10, 2014	N.D. [ $4.6 \times 10^{-7}$ ]	N.D. [ $5.0 \times 10^{-7}$ ]

[ ] shows below the detection limit.

2. Analytical Institution

KAKEN Inc.

3. Evaluation:

Pu-238 and Pu-239+Pu-240 were not detected in the sample collected this time.

End

Result of Pu Nuclide Analysis of Sub-Drain at Fukushima Daiichi Nuclear Power Station <2/2>

1. Measurement Result:

(Data summarized on June 27)

(Unit: Bq/cm<sup>3</sup>)

Place of Sampling	Date	Pu-238	Pu-239+Pu-240
Unit 2 Sub-Drain	Feb 7, 2014	N.D. [ $5.9 \times 10^{-7}$ ]	N.D. [ $5.9 \times 10^{-7}$ ]
Unit 6 Sub-Drain	Feb 7, 2014	N.D. [ $4.9 \times 10^{-7}$ ]	N.D. [ $5.3 \times 10^{-7}$ ]

[ ] shows below the detection limit.

2. Analytical Institution

KAKEN Inc.

3. Evaluation:

Pu-238 and Pu-239+Pu-240 were not detected in the sample collected this time.

End