

Result of Pu Nuclide Analysis of Sub-Drain at Fukushima Daiichi Nuclear Power Station

Data summarized on October 31, 2014)

1. Measurement Result:

(Unit: Bq/cm³)

Place of Sampling	Date	Pu-238	Pu-239+Pu-240
Unit 2 Sub-Drain	Jun 13, 2014	N.D. [6.2×10^{-7}]	N.D. [5.3×10^{-7}]
Unit 3 Sub-Drain	Jun 13, 2014	N.D. [7.0×10^{-7}]	N.D. [5.9×10^{-7}]

[] shows below the detection limit.

2. Analytical Institution

KAKEN Inc.

3. Evaluation:

Pu-238 and Pu-239+Pu-240 were not detected in the sample collected this time.

End