


Fukushima Daiichi NPS Survey Map (As of 5:00 PM on February 19, 2014)



Unit : mSv/h

Upper part of concrete-filled vertical shaft
0.25 (After gravel installation)

Atmosphere 1.7
Ground surface 8.5

Atmosphere 1.8
Ground surface 8.5

Bottom of side ditch
30 (Surface)
1.3 (Atmosphere)

Transfer pipe
120 (Surface)
11 (Atmosphere)

Transfer pipe
80 (Surface)
25 (Atmosphere)

Transfer pipe
80 (Surface)
7 (Atmosphere)

Transfer pipe
100 (Surface)
17 (Atmosphere)

In front of the door
of carry-in entrance
3.5

Transfer pipe
160 (Surface)
18 (Atmosphere)

Unit 1
R/B

Unit 2
R/B

Unit 3
R/B

Unit 4
R/B

Transfer pipe
2.7 (Surface)
1.5 (Atmosphere)

Units 1-2
SGTS pipe
>10,000

Transfer pipe
1 (Atmosphere)

Transfer pipe
0.10 (Atmosphere)

Transfer pipe
5.5 (Surface)
1.5 (Atmosphere)

Transfer pipe
15 (Surface)
1.6 (Atmosphere)

0.50
(Rooftop)

- | | |
|--------------|----------------|
| July 2011 | November 2012 |
| March 2012 | December 2012 |
| June 2012 | March 2013 |
| July 2012 | June 2013 |
| October 2012 | July 2013 |
| | September 2013 |
| | November 2013 |

February 7, 17, 14, 2014