

Fukushima Daiichi NPS Survey Map (As of 5:00 PM on November 10, 2014)



Unit: mSv/h

Upper part of concrete-filled vertical shaft  
0.25 (after gravel installation)

Atmosphere 1.7  
Ground surface 8.5

Atmosphere 1.8  
Ground surface 8.5

Bottom of side ditch 30 (Surface)  
1.3 (Atmosphere)

Transfer pipe 1.2 (Surface)  
0.80 (Atmosphere)

Transfer pipe 0.10 (Surface)  
0.060 (Atmosphere)

In front of the door of carry-in entrance 3.5

Transfer pipe 1.5 (Surface)  
1.0 (Atmosphere)

Transfer pipe 80 (Surface)  
10 (Atmosphere)

Unit 1, 2  
SGTS pipe  
>10,000

Unit 1  
R/B

Unit 2  
R/B

Unit 3  
R/B

Unit 4  
R/B

Transfer pipe 0.35 (Surface)  
0.065 (Atmosphere)

Transfer pipe 0.18 (Surface)  
0.18 (Atmosphere)

- July 2011
- December 2012
- June 2012
- March 2013
- July 2012
- June 2013
- October 2012
- July 2013
- November 2012
- September 2013
- November 2013
- April 2014
- June 2014
- July 2014
- November 2014

