

Monitoring data at Fukushima Daini Nuclear Power Station

MP-5: Data unavailable due to replacement of the high dose rate monitoring equipment (9:10 am ~ 6:10 pm)

※"-": the wind velocity is below 0.5m/s

unit: μ Sv/h

Date	MP							Stuck		Rain
	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7	Wind Direction	Wind Velocity(m/s)	
2012/4/3 0:00	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	7.2	No
2012/4/3 0:10	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	7.2	No
2012/4/3 0:20	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	7.8	No
2012/4/3 0:30	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	8.0	No
2012/4/3 0:40	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	7.8	No
2012/4/3 0:50	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	6.3	No
2012/4/3 1:00	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	5.5	No
2012/4/3 1:10	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	5.7	No
2012/4/3 1:20	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	5.9	No
2012/4/3 1:30	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	6.4	No
2012/4/3 1:40	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	6.2	No
2012/4/3 1:50	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	6.9	No
2012/4/3 2:00	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	6.8	No
2012/4/3 2:10	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	6.6	No
2012/4/3 2:20	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	5.4	No
2012/4/3 2:30	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	5.3	No
2012/4/3 2:40	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	6.5	No
2012/4/3 2:50	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	5.2	No
2012/4/3 3:00	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	6.2	No
2012/4/3 3:10	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	6.0	No
2012/4/3 3:20	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	4.1	No
2012/4/3 3:30	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	4.4	No
2012/4/3 3:40	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	4.6	No
2012/4/3 3:50	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south	4.4	No
2012/4/3 4:00	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south	4.7	No
2012/4/3 4:10	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south	5.2	No
2012/4/3 4:20	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southeast	2.5	No
2012/4/3 4:30	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southeast	1.8	No
2012/4/3 4:40	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southeast	2.4	No
2012/4/3 4:50	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southeast	2.0	No
2012/4/3 5:00	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southeast	2.2	No
2012/4/3 5:10	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southeast	3.2	No
2012/4/3 5:20	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south	4.5	No
2012/4/3 5:30	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south	6.5	No
2012/4/3 5:40	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south	6.4	No
2012/4/3 5:50	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south	6.8	No
2012/4/3 6:00	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south	7.1	No
2012/4/3 6:10	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	6.8	No
2012/4/3 6:20	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	7.4	No
2012/4/3 6:30	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	9.6	No
2012/4/3 6:40	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south	7.9	No
2012/4/3 6:50	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south	6.8	No
2012/4/3 7:00	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south	6.5	No
2012/4/3 7:10	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	8.0	No
2012/4/3 7:20	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	9.1	No
2012/4/3 7:30	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	11.3	No
2012/4/3 7:40	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	11.6	No
2012/4/3 7:50	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	12.0	No
2012/4/3 8:00	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	12.9	No
2012/4/3 8:10	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	12.7	No
2012/4/3 8:20	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	13.9	No
2012/4/3 8:30	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	14.6	No
2012/4/3 8:40	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	13.2	No
2012/4/3 8:50	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south	14.9	No
2012/4/3 9:00	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	16.5	No

Monitoring data at Fukushima Daini Nuclear Power Station

MP-5: Data unavailable due to replacement of the high dose rate monitoring equipment (9:10 am ~ 6:10 pm)

※"-": the wind velocity is below 0.5m/s

unit: μ Sv/h

Date	MP							Stuck		Rain
	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7	Wind Direction	Wind Velocity(m/s)	
2012/4/3 9:10	1.5	1.0	1.5	1.3	-	0.7	0.5	south-southwest	15.8	No
2012/4/3 9:20	1.5	1.0	1.5	1.3	-	0.7	0.5	south-southwest	13.1	No
2012/4/3 9:30	1.5	1.0	1.5	1.3	-	0.7	0.5	south-southwest	14.3	No
2012/4/3 9:40	1.5	1.0	1.5	1.3	-	0.7	0.5	south-southwest	13.0	No
2012/4/3 9:50	1.5	1.0	1.5	1.3	-	0.7	0.5	south	13.8	No
2012/4/3 10:00	1.5	1.0	1.5	1.3	-	0.7	0.5	south-southwest	12.4	No
2012/4/3 10:10	1.5	1.0	1.5	1.3	-	0.7	0.5	south-southwest	12.2	No
2012/4/3 10:20	1.5	1.0	1.5	1.3	-	0.7	0.5	south	11.6	No
2012/4/3 10:30	1.5	1.0	1.5	1.3	-	0.7	0.5	south-southwest	12.5	No
2012/4/3 10:40	1.5	1.0	1.5	1.3	-	0.7	0.5	south-southwest	14.9	No
2012/4/3 10:50	1.5	1.0	1.5	1.3	-	0.7	0.5	south-southwest	17.0	No
2012/4/3 11:00	1.5	1.0	1.5	1.3	-	0.7	0.5	south	13.5	No
2012/4/3 11:10	1.5	1.0	1.5	1.3	-	0.7	0.5	south	12.4	No
2012/4/3 11:20	1.5	1.0	1.5	1.3	-	0.7	0.5	south	13.1	No
2012/4/3 11:30	1.5	1.0	1.5	1.3	-	0.7	0.5	south	13.3	No
2012/4/3 11:40	1.5	1.0	1.5	1.3	-	0.7	0.5	south	13.4	No
2012/4/3 11:50	1.5	1.0	1.5	1.3	-	0.7	0.5	south	13.4	No
2012/4/3 12:00	1.5	1.0	1.5	1.3	-	0.7	0.5	south	12.9	No
2012/4/3 12:10	1.5	1.0	1.5	1.3	-	0.7	0.5	south	12.7	No
2012/4/3 12:20	1.5	1.0	1.5	1.3	-	0.7	0.5	south	12.3	No
2012/4/3 12:30	1.5	1.0	1.5	1.3	-	0.7	0.5	south	11.2	No
2012/4/3 12:40	1.5	1.0	1.5	1.3	-	0.7	0.5	south-southwest	11.6	No
2012/4/3 12:50	1.5	1.0	1.5	1.3	-	0.7	0.5	south-southwest	11.8	No
2012/4/3 13:00	1.5	1.0	1.5	1.3	-	0.7	0.5	south	11.9	No
2012/4/3 13:10	1.5	1.0	1.5	1.3	-	0.7	0.5	south	12.7	No
2012/4/3 13:20	1.5	1.0	1.5	1.3	-	0.7	0.5	south	12.1	No
2012/4/3 13:30	1.5	1.0	1.5	1.3	-	0.7	0.5	south	14.1	No
2012/4/3 13:40	1.5	1.0	1.5	1.3	-	0.7	0.5	south	12.7	No
2012/4/3 13:50	1.5	1.0	1.5	1.3	-	0.7	0.5	south	14.2	No
2012/4/3 14:00	1.5	1.0	1.5	1.3	-	0.7	0.5	south	14.7	No
2012/4/3 14:10	1.5	1.0	1.5	1.3	-	0.7	0.5	south	12.9	No
2012/4/3 14:20	1.5	1.0	1.5	1.3	-	0.7	0.5	south	13.4	No
2012/4/3 14:30	1.5	1.0	1.5	1.3	-	0.7	0.5	south-southwest	13.3	No
2012/4/3 14:40	1.5	1.0	1.5	1.3	-	0.7	0.5	south-southwest	16.1	No
2012/4/3 14:50	1.5	1.0	1.5	1.3	-	0.7	0.5	south	13.1	No
2012/4/3 15:00	1.5	1.0	1.5	1.3	-	0.7	0.5	south	16.9	No
2012/4/3 15:10	1.5	1.0	1.5	1.3	-	0.7	0.5	south-southwest	14.9	Yes
2012/4/3 15:20	1.5	1.0	1.5	1.3	-	0.7	0.5	south-southwest	19.3	No
2012/4/3 15:30	1.5	1.0	1.5	1.3	-	0.7	0.5	south-southwest	15.8	No
2012/4/3 15:40	1.5	1.0	1.5	1.3	-	0.7	0.5	south-southwest	16.4	No
2012/4/3 15:50	1.5	1.0	1.5	1.3	-	0.7	0.5	south	17.9	No
2012/4/3 16:00	1.5	1.0	1.5	1.3	-	0.7	0.5	south-southwest	15.6	Yes
2012/4/3 16:10	1.5	1.0	1.5	1.3	-	0.7	0.5	south-southwest	13.2	Yes
2012/4/3 16:20	1.5	1.0	1.5	1.3	-	0.7	0.5	south-southwest	18.7	Yes
2012/4/3 16:30	1.5	1.0	1.5	1.3	-	0.7	0.5	south-southwest	23.2	Yes
2012/4/3 16:40	1.5	1.0	1.5	1.3	-	0.7	0.5	south-southwest	17.0	Yes
2012/4/3 16:50	1.5	1.0	1.5	1.3	-	0.7	0.5	south-southwest	22.1	Yes
2012/4/3 17:00	1.5	1.0	1.5	1.3	-	0.7	0.5	south	28.4	Yes
2012/4/3 17:10	1.5	1.0	1.5	1.3	-	0.7	0.5	south-southwest	25.9	Yes
2012/4/3 17:20	1.5	1.0	1.5	1.3	-	0.7	0.5	south-southwest	22.1	No
2012/4/3 17:30	1.5	1.0	1.5	1.3	-	0.7	0.5	south	21.4	Yes
2012/4/3 17:40	1.5	1.0	1.5	1.3	-	0.7	0.5	south	23.7	Yes
2012/4/3 17:50	1.5	1.0	1.5	1.3	-	0.7	0.5	south-southwest	23.0	Yes
2012/4/3 18:00	1.5	1.0	1.5	1.3	-	0.7	0.5	south-southwest	25.1	Yes
2012/4/3 18:10	1.5	1.0	1.5	1.3	-	0.7	0.5	south	23.0	Yes

Monitoring data at Fukushima Daini Nuclear Power Station

MP-5: Data unavailable due to replacement of the high dose rate monitoring equipment (9:10 am ~ 6:10 pm)

※"-": the wind velocity is below 0.5m/s

unit: μ Sv/h

Date	MP							Stuck		Rain
	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7	Wind Direction	Wind Velocity(m/s)	
2012/4/3 18:20	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south	19.6	Yes
2012/4/3 18:30	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south	19.2	Yes
2012/4/3 18:40	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	26.2	Yes
2012/4/3 18:50	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south	21.4	Yes
2012/4/3 19:00	1.5	1.0	1.4	1.3	1.2	0.7	0.5	south-southwest	28.1	Yes
2012/4/3 19:10	1.5	1.0	1.4	1.3	1.2	0.7	0.5	south	25.9	Yes
2012/4/3 19:20	1.5	1.0	1.4	1.3	1.2	0.7	0.5	south	22.8	Yes
2012/4/3 19:30	1.5	1.0	1.4	1.3	1.2	0.7	0.5	south	22.7	Yes
2012/4/3 19:40	1.4	1.0	1.4	1.3	1.2	0.7	0.5	south-southwest	16.0	Yes
2012/4/3 19:50	1.4	1.0	1.4	1.3	1.2	0.7	0.5	south-southwest	18.4	Yes
2012/4/3 20:00	1.4	1.0	1.4	1.2	1.2	0.7	0.5	south-southwest	25.4	Yes
2012/4/3 20:10	1.4	1.0	1.4	1.2	1.2	0.7	0.5	south-southwest	20.9	Yes
2012/4/3 20:20	1.4	0.9	1.4	1.2	1.2	0.7	0.5	south	16.8	Yes
2012/4/3 20:30	1.4	1.0	1.4	1.3	1.2	0.7	0.5	south-southwest	19.6	Yes
2012/4/3 20:40	1.4	1.0	1.4	1.3	1.2	0.7	0.5	south-southwest	22.0	Yes
2012/4/3 20:50	1.4	1.0	1.4	1.3	1.2	0.7	0.5	south-southwest	20.0	Yes
2012/4/3 21:00	1.5	1.0	1.4	1.3	1.2	0.7	0.5	south	16.6	Yes
2012/4/3 21:10	1.5	1.0	1.4	1.3	1.2	0.7	0.5	south-southwest	15.8	Yes
2012/4/3 21:20	1.4	1.0	1.4	1.3	1.2	0.7	0.5	southwest	15.4	Yes
2012/4/3 21:30	1.4	0.9	1.4	1.3	1.2	0.7	0.5	west-northwest	8.8	Yes
2012/4/3 21:40	1.4	0.9	1.4	1.2	1.2	0.7	0.5	west-northwest	7.8	Yes
2012/4/3 21:50	1.4	0.9	1.4	1.2	1.2	0.7	0.5	west	5.2	Yes
2012/4/3 22:00	1.4	0.9	1.4	1.2	1.2	0.7	0.5	west-northwest	9.7	Yes
2012/4/3 22:10	1.4	0.9	1.4	1.2	1.2	0.7	0.5	west-northwest	8.2	Yes
2012/4/3 22:20	1.4	0.9	1.4	1.3	1.2	0.7	0.5	west-northwest	7.6	Yes
2012/4/3 22:30	1.4	0.9	1.4	1.3	1.2	0.7	0.5	west-northwest	11.0	Yes
2012/4/3 22:40	1.4	0.9	1.4	1.3	1.2	0.7	0.5	west-northwest	14.0	Yes
2012/4/3 22:50	1.4	0.9	1.4	1.3	1.2	0.7	0.5	west-northwest	16.0	Yes
2012/4/3 23:00	1.4	0.9	1.4	1.3	1.2	0.7	0.5	west	18.2	Yes
2012/4/3 23:10	1.4	1.0	1.4	1.3	1.2	0.7	0.5	west	17.0	Yes
2012/4/3 23:20	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west	11.0	Yes
2012/4/3 23:30	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west-northwest	10.5	Yes
2012/4/3 23:40	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west	13.5	Yes
2012/4/3 23:50	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west	12.1	No

Fukushima Daini Nuclear Power Plant

2012/4/3
as of 23:50

MP1 : 1.5 μ Sv/h (as of 23:50, April 3)
(reference : 0.035 ~ 0.054 μ Sv/h)

MP2 : 1.0 μ Sv/h (as of 23:50, April 3)
(reference: 0.042 ~ 0.062 μ Sv/h)

MP3 : 1.4 μ Sv/h (as of 23:50, April 3)
(reference: 0.036 ~ 0.052 μ Sv/h)


MP4 : 1.3 μ Sv/h (as of 23:50, April 3)
(reference: 0.036 ~ 0.052 μ Sv/h)

MP5 : 1.2 μ Sv/h (as of 23:50, April 3)
(reference: 0.040 ~ 0.058 μ Sv/h)

MP6 : 0.7 μ Sv/h (as of 23:50, April 3)
(reference: 0.044 ~ 0.064 μ Sv/h)

MP7 : 0.5 μ Sv/h (as of 23:50, April 3)
(reference: 0.043 ~ 0.062 μ Sv/h)

モニタリングポスト配置図 2F



※Reference data indicate the normal fluctuation range of airborne radiation rate.