

Monitoring data at Fukushima Daini Nuclear Power Station

MP-5: Data unavailable due to replacement of the high dose rate monitoring equipment (9:10 am ~ 4:30 pm)

※"-": the wind velocity is below 0.5m/s

unit: μ Sv/h

Date	MP							Stuck		Rain
	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7	Wind Direction	Wind Velocity(m/s)	
2012/4/4 0:00	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west	16.0	No
2012/4/4 0:10	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west	14.7	No
2012/4/4 0:20	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west	13.0	No
2012/4/4 0:30	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west-southwest	14.5	No
2012/4/4 0:40	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west	9.8	No
2012/4/4 0:50	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west	11.1	No
2012/4/4 1:00	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west-southwest	11.2	No
2012/4/4 1:10	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west-northwest	14.5	No
2012/4/4 1:20	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west	11.7	No
2012/4/4 1:30	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west-southwest	20.1	No
2012/4/4 1:40	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west-southwest	15.5	No
2012/4/4 1:50	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west-southwest	18.2	No
2012/4/4 2:00	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west-southwest	20.6	No
2012/4/4 2:10	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west-southwest	18.5	No
2012/4/4 2:20	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west-southwest	16.8	No
2012/4/4 2:30	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west-southwest	14.6	No
2012/4/4 2:40	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west-southwest	18.7	No
2012/4/4 2:50	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west-southwest	20.9	No
2012/4/4 3:00	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west-southwest	26.8	No
2012/4/4 3:10	1.5	1.0	1.4	1.3	1.2	0.7	0.5	west-southwest	19.8	No
2012/4/4 3:20	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	21.4	No
2012/4/4 3:30	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	22.9	No
2012/4/4 3:40	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	13.8	Yes
2012/4/4 3:50	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	13.5	No
2012/4/4 4:00	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west	15.1	Yes
2012/4/4 4:10	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	10.8	Yes
2012/4/4 4:20	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	15.9	No
2012/4/4 4:30	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	12.0	No
2012/4/4 4:40	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	10.5	No
2012/4/4 4:50	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	10.5	No
2012/4/4 5:00	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	6.3	No
2012/4/4 5:10	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	4.7	No
2012/4/4 5:20	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	4.7	No
2012/4/4 5:30	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	8.3	No
2012/4/4 5:40	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	9.1	No
2012/4/4 5:50	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	8.5	No
2012/4/4 6:00	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	8.7	Yes
2012/4/4 6:10	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	9.5	Yes
2012/4/4 6:20	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	7.2	Yes
2012/4/4 6:30	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	6.9	No
2012/4/4 6:40	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	5.7	Yes
2012/4/4 6:50	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west	6.4	No
2012/4/4 7:00	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-northwest	8.2	No
2012/4/4 7:10	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	11.7	Yes
2012/4/4 7:20	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west	8.1	Yes
2012/4/4 7:30	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west	4.1	Yes
2012/4/4 7:40	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	12.4	Yes
2012/4/4 7:50	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	8.8	Yes
2012/4/4 8:00	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	8.8	Yes
2012/4/4 8:10	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	8.5	Yes
2012/4/4 8:20	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	9.5	Yes
2012/4/4 8:30	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	5.2	Yes
2012/4/4 8:40	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	3.8	Yes
2012/4/4 8:50	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west	6.5	Yes
2012/4/4 9:00	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	13.3	Yes

Monitoring data at Fukushima Daini Nuclear Power Station

MP-5: Data unavailable due to replacement of the high dose rate monitoring equipment (9:10 am ~ 4:30 pm)

※"-": the wind velocity is below 0.5m/s

unit: μ Sv/h

Date	MP							Stuck		Rain
	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7	Wind Direction	Wind Velocity(m/s)	
2012/4/4 9:10	1.5	1.0	1.5	1.3	-	0.7	0.5	west-southwest	11.5	No
2012/4/4 9:20	1.5	1.0	1.5	1.3	-	0.7	0.5	west	14.6	No
2012/4/4 9:30	1.5	1.0	1.5	1.3	-	0.7	0.5	west	10.9	No
2012/4/4 9:40	1.5	1.0	1.5	1.3	-	0.7	0.5	west	10.5	No
2012/4/4 9:50	1.5	1.0	1.5	1.3	-	0.7	0.5	west-northwest	7.2	No
2012/4/4 10:00	1.5	1.0	1.5	1.3	-	0.7	0.5	west-northwest	5.6	No
2012/4/4 10:10	1.5	1.0	1.5	1.3	-	0.7	0.5	west	7.5	No
2012/4/4 10:20	1.5	1.0	1.5	1.3	-	0.7	0.5	west	7.7	No
2012/4/4 10:30	1.5	1.0	1.5	1.3	-	0.7	0.5	west	12.7	Yes
2012/4/4 10:40	1.5	1.0	1.5	1.3	-	0.7	0.5	west	14.0	No
2012/4/4 10:50	1.5	1.0	1.5	1.3	-	0.7	0.5	west	9.0	Yes
2012/4/4 11:00	1.5	1.0	1.5	1.3	-	0.7	0.5	west-northwest	16.3	No
2012/4/4 11:10	1.5	1.0	1.5	1.3	-	0.7	0.5	west	16.9	No
2012/4/4 11:20	1.5	1.0	1.5	1.3	-	0.7	0.5	west	16.9	No
2012/4/4 11:30	1.5	1.0	1.5	1.3	-	0.7	0.5	west	14.1	No
2012/4/4 11:40	1.5	1.0	1.5	1.3	-	0.7	0.5	west	15.1	No
2012/4/4 11:50	1.5	1.0	1.5	1.3	-	0.7	0.5	west-northwest	17.0	No
2012/4/4 12:00	1.5	1.0	1.5	1.3	-	0.7	0.5	west	13.2	No
2012/4/4 12:10	1.5	1.0	1.5	1.3	-	0.7	0.5	west-northwest	15.5	No
2012/4/4 12:20	1.5	1.0	1.5	1.3	-	0.7	0.5	west	14.9	No
2012/4/4 12:30	1.5	1.0	1.5	1.3	-	0.7	0.5	west	17.9	No
2012/4/4 12:40	1.5	1.0	1.5	1.3	-	0.7	0.5	west	15.7	Yes
2012/4/4 12:50	1.5	1.0	1.5	1.3	-	0.7	0.5	west	14.9	Yes
2012/4/4 13:00	1.5	1.0	1.5	1.3	-	0.7	0.5	west	11.2	Yes
2012/4/4 13:10	1.5	1.0	1.5	1.3	-	0.7	0.5	west-southwest	11.6	Yes
2012/4/4 13:20	1.5	1.0	1.5	1.3	-	0.7	0.5	west-southwest	9.7	Yes
2012/4/4 13:30	1.5	1.0	1.5	1.3	-	0.7	0.5	west-southwest	12.1	Yes
2012/4/4 13:40	1.5	1.0	1.4	1.3	-	0.7	0.5	west-southwest	14.6	No
2012/4/4 13:50	1.5	1.0	1.5	1.3	-	0.7	0.5	west	12.4	Yes
2012/4/4 14:00	1.5	1.0	1.5	1.3	-	0.7	0.5	west-southwest	12.6	Yes
2012/4/4 14:10	1.5	1.0	1.5	1.3	-	0.7	0.5	west	10.6	Yes
2012/4/4 14:20	1.5	1.0	1.5	1.3	-	0.7	0.5	west-northwest	12.4	No
2012/4/4 14:30	1.5	1.0	1.5	1.3	-	0.7	0.5	west	13.3	No
2012/4/4 14:40	1.5	1.0	1.5	1.3	-	0.7	0.5	west-northwest	11.6	No
2012/4/4 14:50	1.5	1.0	1.5	1.3	-	0.7	0.5	west-northwest	10.2	No
2012/4/4 15:00	1.5	1.0	1.5	1.3	-	0.7	0.5	west	14.2	No
2012/4/4 15:10	1.5	1.0	1.5	1.3	-	0.7	0.5	west-northwest	14.6	No
2012/4/4 15:20	1.5	1.0	1.5	1.3	-	0.7	0.5	west	11.6	No
2012/4/4 15:30	1.5	1.0	1.5	1.3	-	0.7	0.5	west	13.2	No
2012/4/4 15:40	1.5	1.0	1.5	1.3	-	0.7	0.5	west	13.6	No
2012/4/4 15:50	1.5	1.0	1.5	1.3	-	0.7	0.5	west	11.9	Yes
2012/4/4 16:00	1.5	1.0	1.5	1.3	-	0.7	0.5	west	13.5	Yes
2012/4/4 16:10	1.5	1.0	1.5	1.3	-	0.7	0.5	west-northwest	11.0	No
2012/4/4 16:20	1.5	1.0	1.5	1.3	-	0.7	0.5	west	11.6	Yes
2012/4/4 16:30	1.5	1.0	1.5	1.3	-	0.7	0.5	west	11.9	No
2012/4/4 16:40	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west	8.6	No
2012/4/4 16:50	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west	6.6	No
2012/4/4 17:00	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	5.9	No
2012/4/4 17:10	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	6.5	No
2012/4/4 17:20	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west	6.2	No
2012/4/4 17:30	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west	6.5	No
2012/4/4 17:40	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west	4.1	No
2012/4/4 17:50	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	3.7	No
2012/4/4 18:00	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	3.2	No
2012/4/4 18:10	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west	1.9	No

Monitoring data at Fukushima Daini Nuclear Power Station

MP-5:Data unavailable due to replacement of the high dose rate monitoring equipment (9:10 am ~ 4:30 pm)

※"-": the wind velocity is below 0.5m/s

unit: μ Sv/h

Date	MP							Stuck		Rain
	MP-1	MP-2	MP-3	MP-4	MP-5	MP-6	MP-7	Wind Direction	Wind Velocity(m/s)	
2012/4/4 18:20	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	1.6	No
2012/4/4 18:30	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	1.9	No
2012/4/4 18:40	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	3.6	No
2012/4/4 18:50	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	4.1	No
2012/4/4 19:00	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	2.7	No
2012/4/4 19:10	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	3.8	No
2012/4/4 19:20	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	3.4	No
2012/4/4 19:30	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	4.5	No
2012/4/4 19:40	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	4.0	No
2012/4/4 19:50	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	5.0	No
2012/4/4 20:00	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	6.2	No
2012/4/4 20:10	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	7.3	No
2012/4/4 20:20	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	8.4	No
2012/4/4 20:30	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	5.9	No
2012/4/4 20:40	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west	6.1	No
2012/4/4 20:50	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	6.4	No
2012/4/4 21:00	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west	4.6	No
2012/4/4 21:10	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	5.5	No
2012/4/4 21:20	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	4.8	No
2012/4/4 21:30	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	3.5	No
2012/4/4 21:40	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	1.8	No
2012/4/4 21:50	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	1.0	No
2012/4/4 22:00	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	1.3	No
2012/4/4 22:10	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	4.6	No
2012/4/4 22:20	1.5	1.0	1.5	1.3	1.2	0.7	0.5	west-southwest	6.0	No
2012/4/4 22:30	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	7.0	No
2012/4/4 22:40	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	7.2	No
2012/4/4 22:50	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	6.3	No
2012/4/4 23:00	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	6.2	No
2012/4/4 23:10	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	4.9	No
2012/4/4 23:20	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	3.3	No
2012/4/4 23:30	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	1.6	No
2012/4/4 23:40	1.5	1.0	1.5	1.3	1.2	0.7	0.5	southwest	4.1	No
2012/4/4 23:50	1.5	1.0	1.5	1.3	1.2	0.7	0.5	south-southwest	5.1	No

Fukushima Daini Nuclear Power Plant

2012/4/4
as of 23:50

MP1 : 1.5 μ Sv/h (as of 23:50, April 4)
(reference : 0.035 ~ 0.054 μ Sv/h)

MP2 : 1.0 μ Sv/h (as of 23:50, April 4)
(reference: 0.042 ~ 0.062 μ Sv/h)

MP3 : 1.5 μ Sv/h (as of 23:50, April 4)
(reference: 0.036 ~ 0.052 μ Sv/h)


MP4 : 1.3 μ Sv/h (as of 23:50, April 4)
(reference: 0.036 ~ 0.052 μ Sv/h)

MP5 : 1.2 μ Sv/h (as of 23:50, April 4)
(reference: 0.040 ~ 0.058 μ Sv/h)

MP6 : 0.7 μ Sv/h (as of 23:50, April 4)
(reference: 0.044 ~ 0.064 μ Sv/h)

MP7 : 0.5 μ Sv/h (as of 23:50, April 4)
(reference: 0.043 ~ 0.062 μ Sv/h)

モニタリングポスト配置図 2F



※Reference data indicate the normal fluctuation range of airborne radiation rate.