

Reference

Nuclides Analysis Results of the Radioactive Materials in the Air at the Opening of Buildings at Fukushima Daiichi NPS<1/4>

(Data summarized on January 7)

Place of Sampling	3rd Floor of Auxiliary Operation Shared Facility (Around the Machine Hatch)		3rd Floor of Auxiliary Operation Shared Facility (In Fornt of South Stairs)		3rd Floor of Auxiliary Operation Shared Facility (In Fornt of North Stairs)		② Density Limit Specified by the Reactor Regulation (Bq/cm ³) (Density limit in the air which radiation workers breathe in is specified in section 4 of Appendix 2)
	Time of Sampling	Dec 21, 2012 ~ Dec 22, 2012 9:03 AM ~ 3:34 PM	Dec 21, 2012 ~ Dec 22, 2012 9:10 AM ~ 3:28 PM	Dec 21, 2012 ~ Dec 22, 2012 8:56 AM ~ 3:22 PM			
Detected Nuclides (Half-life)	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	
I-131 (Approx. 8 days)	ND	-	ND	-	ND	-	1E-03
Cs-134 (Approx. 2 years)	1.1E-07	0.00	9.4E-08	0.00	7.4E-08	0.00	2E-03
Cs-137 (Approx. 30 years)	2.2E-07	0.00	1.8E-07	0.00	1.5E-07	0.00	3E-03

* This is the nuclides analysis result of the radioactive materials in the air during handling of fuel.

* The radioactivity density is the sum of the volatile nuclides density and the particulate nuclides density.

0.0E-0 is the same as 0.0 x 10⁰

Data of other nuclides is under examination.

* In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

* "ND" indicates that the measurement result is below the detection limit.

The detection limits are as follows. Volatile: I-131: Approx. 4E-8Bq/cm³, Cs-134: Approx.7E-8Bq/cm³, Cs-137: Approx.9E-8Bq/cm³ Particulate: I-131: Approx. 3E-8Bq/cm³ As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

Nuclides Analysis Results of the Radioactive Materials in the Air at the Opening of Buildings at Fukushima Daiichi NPS<2/4>

(Data summarized on January 7)

Place of Sampling	3rd Floor of Auxiliary Operation Shared Facility (Around the Machine Hatch)		3rd Floor of Auxiliary Operation Shared Facility (In Front of South Stairs)		3rd Floor of Auxiliary Operation Shared Facility (In Front of North Stairs)		② Density Limit Specified by the Reactor Regulation (Bq/cm ³) (Density limit in the air which radiation workers breathe in is specified in section 4 of Appendix 2)
	Time of Sampling	Dec 24, 2012 8:53 AM ~ Dec 25, 2012 8:54 AM	Dec 24, 2012 9:01 AM ~ Dec 25, 2012 9:00 AM	Dec 24, 2012 8:48 AM ~ Dec 25, 2012 8:48 AM			
Detected Nuclides (Half-life)	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	
I-131 (Approx. 8 days)	ND	-	ND	-	ND	-	1E-03
Cs-134 (Approx. 2 years)	1.6E-07	0.00	1.2E-07	0.00	1.6E-07	0.00	2E-03
Cs-137 (Approx. 30 years)	2.7E-07	0.00	2.9E-07	0.00	2.9E-07	0.00	3E-03

* This is the nuclides analysis result of the radioactive materials in the air during handling of fuel.

* The radioactivity density is the sum of the volatile nuclides density and the particulate nuclides density.

O.OE—O is the same as O.O x 10⁰

Data of other nuclides is under examination.

* In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

* "ND" indicates that the measurement result is below the detection limit.

The detection limits are as follows. Volatile: I-131: Approx. 4E-8Bq/cm³, Cs-134: Approx.9E-8Bq/cm³, Cs-137: Approx.1E-7Bq/cm³ Particulate: I-131: Approx. 3E-8Bq/cm³ As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

Nuclides Analysis Results of the Radioactive Materials in the Air at the Opening of Buildings at Fukushima Daiichi NPS<3/4>

(Data summarized on January 7)

Place of Sampling	3rd Floor of Auxiliary Operation Shared Facility (Around the Machine Hatch)		3rd Floor of Auxiliary Operation Shared Facility (In Front of South Stairs)		3rd Floor of Auxiliary Operation Shared Facility (In Front of North Stairs)		② Density Limit Specified by the Reactor Regulation (Bq/cm ³) (Density limit in the air which radiation workers breathe in is specified in section 4 of Appendix 2)
Time of Sampling	Dec 25, 2012 8:58 AM	~ Dec 26, 2012 8:40 AM	Dec 25, 2012 9:05 AM	~ Dec 26, 2012 8:45 AM	Dec 25, 2012 8:53 AM	~ Dec 26, 2012 8:34 AM	
Detected Nuclides (Half-life)	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	
I-131 (Approx. 8 days)	ND	-	ND	-	ND	-	1E-03
Cs-134 (Approx. 2 years)	1.8E-07	0.00	1.9E-07	0.00	2.5E-07	0.00	2E-03
Cs-137 (Approx. 30 years)	3.1E-07	0.00	3.1E-07	0.00	3.4E-07	0.00	3E-03

* This is the nuclides analysis result of the radioactive materials in the air during handling of fuel.

* The radioactivity density is the sum of the volatile nuclides density and the particulate nuclides density.

O.OE—O is the same as O.O x 10⁰

Data of other nuclides is under examination.

* In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

* "ND" indicates that the measurement result is below the detection limit.

The detection limits are as follows. Volatile: I-131: Approx. 4E-8Bq/cm³, Cs-134: Approx.9E-8Bq/cm³, Cs-137: Approx.1E-7Bq/cm³ Particulate: I-131: Approx. 5E-8Bq/cm³ As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.

Nuclides Analysis Results of the Radioactive Materials in the Air at the Opening of Buildings at Fukushima Daiichi NPS<4/4>

(Data summarized on January 7)

Place of Sampling	3rd Floor of Auxiliary Operation Shared Facility (Around the Machine Hatch)		3rd Floor of Auxiliary Operation Shared Facility (In Fornt of South Stairs)		3rd Floor of Auxiliary Operation Shared Facility (In Fornt of North Stairs)		② Density Limit Specified by the Reactor Regulation (Bq/cm ³) (Density limit in the air which radiation workers breathe in is specified in section 4 of Appendix 2)
	Time of Sampling	Dec 26, 2012 8:43 AM ~ Dec 27, 2012 3:33 PM	Dec 26, 2012 8:47 AM ~ Dec 27, 2012 3:38 PM	Dec 26, 2012 8:37 AM ~ Dec 27, 2012 3:29 PM			
Detected Nuclides (Half-life)	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	①Density of Sample (Bq/cm ³)	Scaling Factor (①/②)	
I-131 (Approx. 8 days)	ND	-	ND	-	ND	-	1E-03
Cs-134 (Approx. 2 years)	8.3E-08	0.00	1.2E-07	0.00	9.5E-08	0.00	2E-03
Cs-137 (Approx. 30 years)	1.4E-07	0.00	1.4E-07	0.00	1.3E-07	0.00	3E-03

* This is the nuclides analysis result of the radioactive materials in the air during handling of fuel.

* The radioactivity density is the sum of the volatile nuclides density and the particulate nuclides density.

O.OE—O is the same as O.O x 10⁰

Data of other nuclides is under examination.

* In the case of more than 2 nuclides, the sum of scaling factors to density limits is compared to 1.

* "ND" indicates that the measurement result is below the detection limit.

The detection limits are as follows. Volatile: I-131: Approx. 3E-8Bq/cm3, Cs-134: Approx.7E-8Bq/cm3, Cs-137: Approx.8E-8Bq/cm3 Particulate: I-131: Approx. 2E-8Bq/cm3 As the detection limit may vary depending on the detectors and sample properties, there are cases where nuclides below the detection limit are detected.